

JINDAL I.V.F. & SANT MEMORIAL NURSING HOME

3050, Sector 20-D, (Behind Shri Guru Ravi Dass Bhavan) Dakshin Marg, Chandigarh-160020

Dr. (Mrs.) Umesh N. Jindal

M.D. (Obstet & Gynae PGI, CHD.)

DIRECTOR

- Former Assistant Professor WHO/CCR, PGI, Chandigarh
- Former Fellow University of Washington, Seattle & R.S.A. Kansas City, USA.
- Member, American Society for Reproductive Medicine, FOGSI/ISAR/IMA/ISOPARB/IFS/ESHRE
- Member, Fertility Preservation Society of India



CLINIC

Monday - Friday 09.00 am to 04.00 pm
Saturday 09.00 am to 02.00 pm
Sunday 11.00 am to 01.00 pm

Phones :

Off. : +91-172-4911100, +91 97790 30507

E-mail : director@ivfchandigarh.com

drunjindal@gmail.com

Website : www.ivfchandigarh.com

Gynae Consultants

- **Dr. Swati Verma**
MBBS, DGO
- **Dr. Anupam Gupta**
MBBS, DGO DNB
- **Dr. Nidhi Sharma**
MBBS, M.S. (Obs & Gynae)
- **Dr. Sheetal Jindal**
MBBS, M.D. (Obs & Gynae)

Embryologists

- **Dr. Sanjeev Maheshwari**
MBBS, MD
- **Mrs. Simmi Maheshwari**
M.Sc.

Facilities

- **Obstetrics**
- **Gynae Care**
 - Infertility
 - Fetal Medicine
 - Laparoscopy
 - Hysteroscopy
 - Gynae Surgery
 - General Surgery
 - Maternity Care
 - Clinical Investigations
 - Lab Investigations
 - Andrology Lab Tests

Chest Consultants

- **Dr. S. K. Jindal**
MBBS, MD, Former Head PGI
- **Dr. Aditya Jindal**
MBBS, DNB., DM

Facilities

- Consultation
- Pulmonary Function Test
- Sleep Studies
- Bronchoscopy & EBUS
- Thoracoscopy
- Lung Cancer Chemotherapy

Ref. No. JISNH /ADMIN /2020/15

Date: -11-05-2021

To

Chandigarh Pollution Control Committee
Ground Floor Paryavaran Bhawan
Madhya Marg Sec 19-B
Chandigarh - 160022


Ref: Consent No - CCPC. RMHP/2871/2015/722/2829

Sub: Submission of Waste water analysis report for the Month of Feb 2021 to April 2021.

Respected Sir,

As required by above referred consent the report of Waste water for the Month of Feb 2021 to April 2021 is submitted here with.

With Regards


(Dr Umesh N. Jindal)
Director

OPD : JINDAL CLINICS

SCO 21, Sector 20-D, Dakshin Marg, Chandigarh - 160 020
Ph.: +91-172-4911000, +91-97790 30507

Email : director@ivfchandigarh.com; drunjindal@gmail.com, Website : www.ivfchandigarh.com



Idma Laboratories Limited

(A Government Approved Test House)



Certificate No. :
TC-8207

NABL (TC-8207) MOEF/BIS/FSSAI/State Pollution Boards/Drug & Cosmetic Act/ISO 9001; 14001; 18001 Certified

TEST REPORT

Ref. No. IL/D- 2703	Date 05.05.21	Lab No. 300421L-ED-014	Page No. 1/1
Customer	Jindal I.V.F & Sant Memorial Nursing Home # 3050, Sector 20-D (Behind Shri Guru Ravi Dass Bhawan) Dakshin Marg, UT Chandigarh Chandigarh		
Type of Sample	Waste Water		
Customer's Description of Sample	Waste Water (Sewage Water)		
Quantity	5 Ltr.		
Packing, Markings	Plastic Can		
Mode of Collection of Sample	Sampling by Laboratories		
Work Order No.	NIL	Dated	30/04/2021
Date of Receipt of Sample	30/04/2021		
Period of Analysis	30/04/2021 To 04/05/2021		
Sampling Team Idma	Idma Representative Team	Client	Mrs.Umesh N.Jindal
Sampling Location	Sewage Tank		
Visual Observation	N/A		
Date of Sampling	30/04/2021		
Date of Reporting	04/05/2021		
Sampling Protocol	IS:3025-1987		
Testing Protocol	CPCB		

RESULTS

S.No.	Test Parameter	Units	Results	Specifications	Test Method
	CHEMICAL TESTING (Waste Water)	-	-	-	-
1	pH	-	7.34	5.5-9.0	IS 3025 (P-11) 1983 (RA 2017)
2	Chemical Oxygen Demand (COD)	mg/L	92	Max. 350	IS 3025 : Part 58-2006 (RA 2017)
3	Biochemical Oxygen Demand	mg/L	16	Max. 20	IS: 3025 (P-44)-1993 (RA 2014) BOD 3-days at 27 °C
4	Oil & Grease	mg/L	2.6	-	IS 3025 (P-39) 1991 (RA 2014) Partition Gravimetric Method
5	Total Dissolved Solids (TDS)	mg/L	605	-	IS 3025 (P-16) 1984 (RA 2017)
6	Total Suspended Solids (TSS)	mg/L	40	Max. 600	IS 3025 (P-17) 1984 (RA 2017)

End of Report

Analyst *[Signature]*
04/05/21

For Idma Laboratories Limited

Authorized Signatory
TM/II/III

